## CALIFORNIA AIR RESOURCES BOARD MONTHLY QUALITY MAINTENANCE CHECK SHEET ADI MODEL ANNE/TANN OZONE ANALYZED

Location: M Station Number: T		onth/Year: echnician:
Property Number:		Agency:
1 3	· ·	
	Test Parameters	Readings
	DATE	i i i i i i i i i i i i i i i i i i i
TIME (PST)	Current Time (HH:MM)	
RANGE	500 ppb	
STABIL	< 1.0 with zero air (Record Only)	
O3 MEAS	2500-4900 mV	
O3 REF	2500-4900 mV	
**O3 GEN	80-5000 mV (Record Only)	<del>                                     </del>
**O3 DRIVE	0-5000 mV (Record Only)	
PRES	0-2" Hg below ambient (Record Only)	
*SAMPLE FLOW	720 ± 80 cc/min	
SAMPLE TEMP		
PHOTO LMP	Station Temp ± 15°C	<del>                                     </del>
**O3 GEN TEMP	Photo Lamp Temp. 58 ± 1°C	
BOX TEMP	O3 Generator Temp. 48 ± 3°C	
	Station Temp ± 8°C	
SLOPE	1.0 ± 0.15 – No Changes	
* - per the Standard Ope	< ± 5 ppb – No Changes	r standard than originally stated by the Federal
Figure Standard Ope EPA Equivalency Design		r standard than originally stated by the rederal
** = applicable for the IZ		
	STICKIC.	
OPERATOR INSTRUC	JIIONS:	
1. Daily checks:	Review data and data system graphs of	or strip charts.
2. Weekly Checks:	Record test parameters.	·
O O O O Ammunali	Change 5 µm PTFE particulate filter D	ate:/// Date last performed:
3. Semi-Annual: 4. Annual:	Calibrate analyzer. Replace Sintered Filter / O-Rings	Date last performed: Date last performed:
5. As Required:	Clean optical chamber.	Date last performed:
o. 7.0 1.0 qu 2	Adjust photo lamp when O3 ref < 2500	mV. Date last performed:
	Rebuild the pump.	Date last performed:
	Replace O3 scrubber	Date last performed:
D. ( )   O	NACCOLO SE DE Managera	
Date Comm	ents or Maintenance Performed:	

Reviewed by: \_\_